

South Nyanza Sugar Company Limited


P.O. Box 107, CODE 40405, SARE – AWENDO (KENYA)

TELEPHONE: 059 – 43620, 43621, 43622

MOBILE: 0722 – 205345, 205346, 205347

0733 – 333348, 333349, 333350

FAX: 059 – 43245, 0722 – 542422



SONYSUGAR
Simply The Sweetest

ADDENDUM NUMBER ONE (1)

**TENDER NO. SNSC/451/2023/2024 “SUPPLY,
INSTALLATION, CONFIGURATION, TESTING AND
COMMISSIONING OF 40 KVA DATA CENTRE SMART
UPS”**

CLARIFICATIONS ON TENDER ADVERTISEMENT

S/ No.	Area of Clarification	Description	Clarification(s)
1.	Tender Security, Model of existing UPS and Batteries specs indicated	<p>1.0 Tender sent out indicated no tender security in pg. 2 and ITT 18.1 in the Tender Data Sheet. However the same was included as a mandatory requirement in evaluation criteria.</p> <p>2.0 Model of UPS, Batteries not indicated.</p>	<p>Tender Security is a requirement and has been updated in the Tender Document.</p> <p>Bidders are required to quote for available models in the market and supply the 40KVA UPS ONLY.</p> <p>The batteries (12VDC 100AH-40Pcs) are on site awaiting fitting and thus the batteries are not to be supplied (refer to the updated Tender document)</p>